LISTING SERVICE

LISTING No.   7770-1209:140   Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: System Sensor, 3825 Ohio Ave, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models WFD20, -25, -30, -35, -40, -50, -60, -80, WFD-30-2, WFDT, WFDTH, WFDTNR, AFD20, -25, -30-2, -35, -40, -50, -60, -80, -AFDT, -AFDTH and RFDTH paddle-type waterflow indicators. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Model	Size	Working Pressure
AFD20, WFD20	2"	450 psig
AFD25, WFD25	2-1/2"	450 psig
WFD30	3"	450 psig
AFD30-2, WFD30-2	3"	450 psig
AFD35, WFD35	3-1/2"	450 psig
AFD40, WFD40	4"	450 psig
AFD50, WFD50	5"	450 psig
AFD60, WFD60	6"	450 psig
AFD80, WFD80	8"	450 psig
AFDT, WFDT	1", 1-1/4", 1-1/2"	250 psig
WFDTNR	1", 1-1/4", 1-1/2", 2"	250 psig
AFDTH, WFDTH	1", 1-1/2"	250 psig
RFDTH	1", 1-1/2", 2" Reliable Riser	250 psig

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as waterflow indicators for use with wet pipe fire sprinkler systems.

*Rev. 06-16-2003

Date Issued: **JUNE 22, 2004**   *Listing Expires* **June 30, 2005**

A*uthorized By:*   **DIANE K. AREND**, *Senior Deputy*
Program Manager